

This chart shows the results of items found in our drinking water. All numbers — except those for bacteria, chlorine and pH — represent the amount of a chemical in parts per billion. The bacteria results represent amounts of coliform colonies per hundred milliliters. A 0 means that the location is in compliance with Environmental Protection Agency standards. The normal chlorine level for municipal water should be around 0.5, while the normal pH level should be around 7.0.

	Pottstown 1	Pottstown 2	Pottstown 3	Spring City	Royersford	Phoenixville	Collegeville	Trappe	Bally	Boyertown 1	Boyertown 2
1, 2-Dichloroethane											
1, 1, 1-Trichloroethane	0.40	0.47	0.37	0.05	0.07	0.13	0.27	2.5	18		
1, 1-Dichloroethane							0.06 +	0.03 +			
Chloroform	8.9	17	24	24	31	36		0.04		25	17
1, 1-Dichloroethene								0.37	6.9		
trans-1, 2-Dichloroethene											
Methylene chloride	0.99●										
Bromoform								0.86			
Bromodichloromethane	4.9	9.8	5.8	9.6	12	7.5	0.38	0.38		5.0	3.6
Chlorodibromomethane	2.8	6.2	0.89	4.3	5.6	0.34	0.10	1.4		0.32	0.18
Tetrachloroethylene (PCE)					0.02		6.3●	1.0		0.32	
Trichloroethylene (TCE)	0.21●	0.44●	0.13●		0.02●		28●●	1.7●	2.7●		
Bacteria count	0	0	0	0	0/0	0	0	2/0	0	0	0
Chlorine level	1.0	0.5	0.5	1.5	0.5	1.0	0	0	0	0.5	1.0
pH factor	7.5	7.5	7.5	7.0	7.0	7.0	7.5	7.5	6.5	7.0	7.0
Benzene											
Toluene											
Ethyl Benzene											
M & P Xylene											
O-Xylene											

+ RECOMMENDED LEVEL UNKNOWN



